

<ul style="list-style-type: none"> ○ Female rooms, wash facilities and toilets have a lockable door ○ Basic First-aid ○ Written agreement between employers on First-aid coverage for their workers staying in camp ○ Safe Premises ○ Safe Machinery and Equipment ○ Emergency Preparedness ○ Emergency Response Plan, Evacuation Plan ○ Violence in the Workplace ○ Exposure Control Plan and Procedures – OH&S Reg 5.54 for Air contaminants, Bio-hazards(sharps), Hygiene and infectious diseases ○ Lock-out or De-energization of equipment or machinery ○ Fall Protection for Roof work or work over 10 feet ○ Electrical generator properly grounded ○ Protection of compressed Gas ○ Garbage and Waste storage must be 10 meters from any building ○ Fuel storage is compliant with the Fire Permit. All fuel Storage vessels grounded, includes Trailers with fuel (such as Propane tanks) attached ○ Carbon Monoxide detectors required near all carbon producing appliances (110 volt hard wired) 	<p>3.16</p> <p>4.1</p> <p>4.3</p> <p>4.13(1)</p> <p>4.2.7</p> <p>5.54</p> <p>10.2</p> <p>11.3</p> <p>5.36</p>	<p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p> <p><input type="checkbox"/></p>
<p>COMPLEX - 6 rooms or more</p> <ul style="list-style-type: none"> ○ Fire Detection System - 110 volt hard wired system ○ All sleeping units – heat detectors wired into central alarm, smoke alarms not wired into central alarm system (after Nov 2006 new code does not require heat detectors; now called Fire Detectors. But prior installations must retain and maintain heat detectors) ○ Fire System detection panel ○ Pull stations in hall ways ○ Fire detectors in mechanical areas; i.e. over furnaces, hot water tanks ○ Smoke detectors in hall ways and exit stairways. ○ Fire Detectors required in all enclosures (janitor closets, storage, service laundry rooms) ○ Water hose system for fire-fighting purposes for camps with more than 30 beds 		

<p>SINGLE TRAILER UNITS</p> <ul style="list-style-type: none"> ○ 110 volt hard wired smoke alarm in each room and all interconnected ○ One fire extinguisher on outside of unit mounted mid-point ○ Minimum 10 meters of separation between units, or 1.22 meters end to end with a 45minute fire rating on the end walls ○ Fire Detectors required in all enclosures (janitor closets, storage, service laundry rooms) 		
<p>OTHER JURISDICTIONS</p> <ul style="list-style-type: none"> ○ British Columbia Objective Based Building Code ○ Health Code – food, sanitation, potable water ○ British Columbia Objective Based Fire Code (including reference documents, NFPA (National Fire Publication Association), ULC, CSA) ○ Labour Code ○ Human Rights Code and Law ○ Federal Firearms Law ○ Canadian Electrical Code Part One (Ground fault Circuit Interrupters) 		